

TECHNICAL TERMS OF CONTRACT

Location:

Address: Port of Koper d.d., Container terminal,



Figure 1: Existing APS push plate with marshalling panel

Description of works:

- In order to expand the container terminal, we received a request for the purchase of 10 additional APS push plates.

Offer description:

- Consider transport costs
- All dimensions must be identical to existing APS push plates with marshalling panel
- The guarantee for the work performed must be at least one year
- The APS system, must be equipped with the detection of earth leakage protection, to protect against fault/damage on cable from APS to E-RTG crane. The protection device must be able to communicate remotely (equipped with auxiliary contact wired to the terminals for connection to the controller – in future).
- Every single APS, must be ordered with one extra Castell lock safety system for mounting on circuit breaker in the transformer substation, type K-FSB-25.4-2, with the corresponding FK4-NI type key.

Task list:

1. Delivery and delivery of 10 APS yard single push plate type SC-1502658-PP1 / A.	
2. Delivery and delivery of 10 sets of marshalling panel with all the accessories SC-1502658-BE2..	
3. For all couplings, the three passages (bumpers) for the passage of the cable must be supplied - a total of 30 pieces..	
4. Delivery of complete documentation in 4 copies in paper form + 1 copy on USB stick (maintenance instructions, operating instructions, a-test documentation, plans ...).	